



AVASCO INDUSTRIES nv
 Cardijnlaan 6, 8600 DIKSMUIDE (B)

T + 32(0)55 33 15 70

F + 32(0)55 31 56 03

www.avasco-sprinkler.be

gerrit.kruithof@avasco-sprinkler.be

contactpersoon: Gerrit Kruithof

TECHNISCHE DOCUMENTATIE SPRINKLERWATERTANK

UITVOERING FM
 (=NFPA22)

(Z600)

01-01-2009

Certificaat	FM Approvals ID 3017631 / 3031291 / 3028970 Approval standard 4020/4021 December 2005
Uitvoering	"Bolted/mastic" ontwerp met waterdichte betonvullaag van 200 mm dikte
Fabrikant	Avasco Industries nv te Diksmuide (B)
Capaciteiten	50 m ³ - 1.660 m ³ netto
Afmetingen	zie achterzijde (maximale hoogte 12 meter)
Wanddikte	Min 2,5 mm
Zinklaagdikte	Gegalvaniseerd Z600 conform EN 10327 tabel 3 (300 g/m ² /zijde)
Coating binnenzijde	2 lagen bitumenverf (max. +/- 200 µ)
Onderhoudsvrije termijn	10 jaar aan de binnenzijde
Typierend kenmerk	Mat glanzend met duidelijk zichtbare gewalste zinklaag en wind verstijvingsring(en) op de wand



ID 3017631

ID 3031291

ID 3028970

