



AVASCO INDUSTRIES nv
 Cardijnlaan 6, 8600 DIKSMUIDE (B)

T + 32(0)55 33 15 70

F + 32(0)55 31 56 03

www.avasco-sprinkler.be

gerrit.kruithof@avasco-sprinkler.be

contactpersoon: Gerrit Kruithof

TECHNISCHE DOCUMENTATIE SPRINKLERWATER TANK

MODEL LPCB

Superior Supply Tank (previous type A)

01-01-2009

Certificaat	LPCB 575a/01Ag conform LPS1276/EN12845
Ontwerp	"Bolted/mastic" ontwerp met waterdichte betonvullaag van 200 mm dikte
Fabrikant	Avasco Industries nv te Diksmuide (B)
Capaciteiten	50 m ³ - 1.300 m ³ netto
Afmetingen	Zie achterzijde
Wanddikte	Minimaal 4 mm
Zinklaagdikte	Volbad verzinkt 600 gr/m ² /side
Coating binnenzijde	2 lagen bitumenverf (+/- 200 µ)
Onderhoudsvrije termijn	10 jaar aan de binnenzijde
Typerend kenmerk	Dof en "ruw", kleurverschillen en vlekken zijn onvermijdelijk door het galvanisatieproces



Certificate n° 575a/01Ag

